



Observations on the Impact of Leased Facilities to the Fire Protection Program

DOE Fire Protection Conference
Las Vegas, Nevada
May 2014
Robert Bitter, PE, FSFPE





Old Facility



- 136 land acres
- 38 buildings
- 3.2M sq. ft.
- \$ 3.0B total value
- ~ 50 MFL areas
- Largest MFL -\$250M
- ~2510 FTES





New Facility (will be completed this year)




Leased bldg.

- Located in south KC
- 7 miles south of old facility
- 191 land acres
- 5 buildings
- 1.5M sq. ft.
- \$650M bldg. cost
- \$1.2B total project cost (including move cost)
- Manufacturing Bldg. MFL
 - Manuf. –\$411M
 - Stores \$1B
 - ~3200 FTES
 - Move -in
 - Start 1/2013
 - End 7/2014





Transformation Schedule Summary



Project started in 2010 and will complete this summer.





Fire Protection Requirements

Old Facility

Performance Driven - 1st Code Driven - 2nd

- DOE order 420.1
- NFPA codes (all)
- Factory Mutual (guidance)

New Facility

Code Driven

- DOE order 420.1
- NFPA codes (all)
- Factory Mutual (guidance)
- City Building Codes
- International Building Codes
- International Fire Code (2006)





Fire Protection Staffing

Old Facility

- DOE/NNSA FPE 0
- Honeywell FPE Staff 13
 1
- Subcontractor FPE -1
- Fire Brigade 12 20
- First Aid (provided by Security
- Emergency Management -

- DOE/NNSA FPE 0.
- Honeywell FPE 1
- Subcontractor FPE -1
- Fire Brigade 0
- First Aid/First Responder (provided by Security)
- Emergency Management 1





Emergency Management

Old Facility

Fire Department

NFPA 600 - (1970 - 2008)

Fire Responder and ITM and KC Fire Dept (2008 - 2014)

Response time -

Fire Brigade – 3 min

KC Fire Dept – 5-7

min

New Facility

Fire Department

KC Fire Dept

Response time –

In House First Responder* – 3

Min

KC Fire w/ EMT - 5 min

KC Ambulance – 12 min**

* 1st Aid, AED, CPR, and Blood Borne Pathogens

**Just identified - On June 30, 2014 the nearest KC Dept is being closed which will adversely effect response time - being worked.



Insurance

Old Facility


- Building –
 Government (self insured)
- Content Government (self insured)
- Business Interruption (Mission Impact) -Government (self insured)

- Building Privately insured - \$1.16M
- Content Government (self insured)
- Business Interruption (Mission Impact) -Government (self insured)





Project/Work Request





<u>Players</u>

Old Facility

- NNSA
- Prime Contractor (Honeywell)

- NNSA
- Prime Contractor (Honeywell)
- GSA
- Fire Marshall
- City Building Code Official
- Building Owner
 - Building Owners insurance company
 - A&E
 - Fire Protection Consultant





Authority Having Jurisdiction

Old Facility

Operations and Building

- DOE/NNSA Hq
- NNSA Field Office

Delegated to:

Prime Contractor

Delegated to:

Fire Protection Engineer

New Facility

Operations

- DOE/NNSA Hq
- NNSA Field Office (Area Manager)

Note – All Issues (Big and Small)

Building

City of Kansas City, Mo.





Fire Protection ITM

Old Facility

- NFPA 25 except:
 - 5 yr internal pipe inspection
- All done in house
- Honeywell FTEs 12

- NFPA 25 no exceptions
- Performed by building owner
- Honeywell FTEs 0
- Oversight by Honeywell
- Fire main loop testing performed by subcontractor at Honeywell request and DOE expense (no code driver for the building owner)






Code Modification Request

(Fire Protection Related only)

Old Facility



New Facility

- Chemical Storage building no sprinklers and unlimited H3/H4 (original and 1 revision)
- PVC exhaust ducts not meeting smoke rating
- 1 hr rated roof under penthouse
- Office building firewall not independently supported
- MFL wall downgraded to fire barrier caused by pipe penetrations
- Use of ESFR sprinklers without
 roof vents

We are playing well with the City AH



Exemptions/Equivalencies

Old Facility

Exemptions

- 100% horizontal exits
- Excess travel distance
- Cooling tower construction
- ITM frequency on loop testing

Equivalencies

Major

- Life Safety travel distance
- MFL walls 2 hr instead of 4 hr
- MFL walls with pipe penetrations
- Emergency lights not meeting ft-candles
 - NFPA 25 sprinkler sampling camera inspection

New Facility

Exemptions

- Excessive MFL (\$1B)
- Non FM approved cooling tower (no AS) - pending

Equivalencies

- Use of Class B ovens for small quantity of flammable liquids – pending
- Ultrasonic cleaners using flammable liquids not UL.







KCRIMS Financial Model



All Sites, Includes Requalification, Excludes Disposition





Project on track to meet original financial objectives





Summary

- Total cost savings 25% less operating cost of Old Facility
- State of the Art Fire Protection
- Totally Code Compliant less a few MINOR exemptions/equivalencies
- Bldg Code/IFC MAQs exempted at Old Facility
- More codes to deal with
- Resolution of conflicting codes
- More players
- More paperwork
- More meetings
- AHJ change

Not negative just me whinning (workload increase)





QUESTIONS?

